

# FACT SHEET



**F 11**  
(Issued 18/3/2008)

91 Hammond Avenue, PO Box 456  
Wagga Wagga NSW 2650  
Phone: 02 6922 0608 Fax: 02 6921 2241  
E-mail: admin@rwcc.com.au

## TYPICAL CHEMICAL ANALYSIS

of the water produced at the respective sources are:-

Source	Type	Treatment	.pH	mg/litre CaCO <sup>3</sup>		
				Alkalinity	Ca Hardness	Total Hardness
Wagga Wagga	River	Filtration	7.7	78	41	79
East Wagga	Underground	Lime	7.5	103	31	95
West Wagga	Underground	Aeration	7.2	106	30	80
North Wagga	Underground	Aeration	7.6	104	32	85
Oura	Underground	Aeration	7.3	100	35	78
Urana	Creek	Filtration	7.8	60	50	60
Ralvona	Underground	Aeration	8.0	146	36	90
Walla Walla	Underground	Aeration	8.3	130	53	87
Tarcutta	Underground	Aeration & Filtration	7.8	155	37	105
Humula	Well	Nil	7.2	73	19	72
Morundah	Creek	Filtration	7.9	64	31	52
Woomargama	Underground	Aeration	7.4	110	30	100
Walbundrie/Rand	Underground	Aeration	8.0	179	68	140
Bulgary	Underground	Aeration	7.1	74	18	50
Collingullie	Underground	Filtration	7.2	127	28	86



Routine sampling and testing of all supplies ensures that bacteriological Standards for potable supplies are maintained.